

## Solicitation No. PR10494611 - CMR HVAC upgrade

### Questions and Answers, Number 1

February 18, 2021

Attention interested bidders:

Please see responses the first set of bidders questions for the CMR HVAC upgrade solicitation. Photos and AutoCAD drawings are available upon request. The deadline for submitting bids remains March 1, 2022 at 16:00 hrs. Bangkok time.

**Q1 : Please specify the IP type and Brand of VSD.**

A: Variable Speed Drive (VSD) – use IP20 rated.

- Drawing M-01 – The existing AHU control panel shall remain. The contractor shall install a new VSD control panel in the AHU room.
- There's no specific brand, but all equipment and materials must be met with the standard requirements of the engineering system for the system operation.

**Q2: Request dwg format of CMR-21-Main House 2nd Floor HVAC Upgrade Drawings.**

A : Pictures, Drawings plan, AutoCAD file for this solicitation are available, please contact Khun Poonnakrit Pinla-Or, email: [Pinlaorp@state.gov](mailto:Pinlaorp@state.gov)

**Q3: Request picture overall work.**

A: Pictures, Drawings plan, AutoCAD file for this solicitation are available, please contact Khun Poonnakrit Pinla-Or, email: [Pinlaorp@state.gov](mailto:Pinlaorp@state.gov)

Sincerely,

*Scott Krushinski*

Scott Krushinski

Contracting Officer